

**REPORTED TO** Alto Utilities Ltd.  
10397 Lodge Road  
LAKE COUNTRY, BC Alt td.

**TEL** 1-250-864-7426  
**FAX** (866) 643-7116

**ATTENTION** Larry Fallis

**WORK ORDER** 4110909

**PO NUMBER**

**RECEIVED / TEMP** Nov-18-14 11:38 / 12°C

**PROJECT** Comprehensive

**REPORTED** Nov-25-14

**PROJECT INFO** No Project

**COC NUMBER** B 17417

**General Comments:**

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Issued By:

**Jennifer Shanko, ASCT**  
Administration Coordinator

**Please contact CARO if more information is needed or to provide feedback on our services.**

**Locations:**

#110 4011 Viking Way  
Richmond, BC V6V 2K9  
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N  
Kelowna, BC V1X 5C3  
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue  
Edmonton, AB T5S 1H7  
Tel: 780-489-9100 Fax: 780-489-9700

[www.caro.ca](http://www.caro.ca)

**REPORTED TO PROJECT** Alto Utilities Ltd.  
Comprehensive

**WORK ORDER REPORTED** 4110909  
Nov-25-14

Analysis Description	Method Reference	Technique	Location
Alkalinity (Total)	APHA 2320 B	Titration with H2SO4 to pH 4.5	Kelowna
Anions in Water by IC	APHA 4110 B	Ion Chromatography with Chemical Suppression of Eluent Conductivity	Kelowna
Colour, True	APHA 2120 C *	Spectrophotometry (410 nm)	Kelowna
Conductivity in Water	APHA 2510 B	Conductivity Meter	Kelowna
Cyanide, Total in Liquids	APHA 4500-CN- C / APHA 4500-CN- E	Distillation / Colorimetry	Kelowna
E. coli (CCA)	APHA 9222 *	Membrane Filtration	Kelowna
Hardness (as CaCO3)	APHA 2340 B	Calculation	N/A
pH in Water	APHA 4500-H+ B	Electrometry	Kelowna
Solids, Total Dissolved	APHA 1030 E	Calculation	N/A
Total Coliforms (CCA)	APHA 9222 *	Membrane Filtration	Kelowna
Total Recoverable Metals	APHA 3030E * / APHA 3125 B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Transmissivity at 254 nm	APHA 5910 B	Ultraviolet Absorption	Kelowna
Turbidity	APHA 2130 B	Nephelometry	Kelowna

**Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method**

**Method Reference Descriptions:**

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation

**Glossary of Terms:**

MRL	Method Reporting Limit
<	Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
AO	Aesthetic objective
MAC	Maximum acceptable concentration (health based)
OG	Operational guideline (treated water)
% T	Percent Transmittance
CFU/100 mL	Colony Forming Units per 100 millilitres
CU	Colour Units (referenced against a platinum cobalt standard)
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
pH units	pH < 7 = acidic, pH > 7 = basic
µS/cm	Microsiemens per centimetre

**Standards / Guidelines Referenced in this Report:**

Guidelines for Canadian Drinking Water Quality (Oct 2014)

Website: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/2012-sum\\_guide-res\\_recom/index-eng.php](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/2012-sum_guide-res_recom/index-eng.php)

**Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user**

**REPORTED TO PROJECT** Alto Utilities Ltd.  
Comprehensive

**WORK ORDER REPORTED** 4110909  
Nov-25-14

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

**Sample ID: 10397 Lodge Road (Source) North Well (4110909-01) [Water] Sampled: Nov-18-14 11:00**

**Anions**

Chloride	49.1	AO ≤ 250	0.10	mg/L	N/A	Nov-20-14	
Fluoride	0.19	MAC = 1.5	0.10	mg/L	N/A	Nov-20-14	
Nitrogen, Nitrate as N	0.733	MAC = 10	0.010	mg/L	N/A	Nov-20-14	
Nitrogen, Nitrite as N	< 0.010	MAC = 1	0.010	mg/L	N/A	Nov-20-14	
Sulfate	65.0	AO ≤ 500	1.0	mg/L	N/A	Nov-20-14	

**General Parameters**

Alkalinity, Total as CaCO3	265	N/A	1	mg/L	N/A	Nov-18-14	
Colour, True	< 5	AO ≤ 15	5	CU	N/A	Nov-19-14	
Conductivity (EC)	780	N/A	2	µS/cm	N/A	Nov-18-14	
Cyanide, total	< 0.010	MAC = 0.2	0.010	mg/L	Nov-19-14	Nov-19-14	
pH	7.98	6.5-8.5	0.01	pH units	N/A	Nov-18-14	
Turbidity	0.4	OG < 0.1	0.1	NTU	N/A	Nov-19-14	
UV Transmittance @ 254nm	97.0	N/A	0.1	% T	N/A	Nov-21-14	

**Calculated Parameters**

Hardness, Total (Total as CaCO3)	370	N/A	5.0	mg/L	N/A	N/A	
Solids, Total Dissolved	451	AO ≤ 500	2.0	mg/L	N/A	N/A	

**Total Recoverable Metals**

Aluminum, total	< 0.05	OG < 0.1	0.05	mg/L	Nov-19-14	Nov-21-14	
Antimony, total	< 0.001	MAC = 0.006	0.001	mg/L	Nov-19-14	Nov-21-14	
Arsenic, total	< 0.005	MAC = 0.01	0.005	mg/L	Nov-19-14	Nov-21-14	
Barium, total	0.06	MAC = 1	0.05	mg/L	Nov-19-14	Nov-21-14	
Beryllium, total	< 0.001	N/A	0.001	mg/L	Nov-19-14	Nov-21-14	
Boron, total	< 0.04	MAC = 5	0.04	mg/L	Nov-19-14	Nov-21-14	
Cadmium, total	< 0.0001	MAC = 0.005	0.0001	mg/L	Nov-19-14	Nov-21-14	
Calcium, total	91.8	N/A	2.0	mg/L	Nov-19-14	Nov-21-14	
Chromium, total	< 0.005	MAC = 0.05	0.005	mg/L	Nov-19-14	Nov-21-14	
Cobalt, total	< 0.0005	N/A	0.0005	mg/L	Nov-19-14	Nov-21-14	
Copper, total	< 0.002	AO ≤ 1	0.002	mg/L	Nov-19-14	Nov-21-14	
Iron, total	0.12	AO ≤ 0.3	0.10	mg/L	Nov-19-14	Nov-21-14	
Lead, total	< 0.001	MAC = 0.01	0.001	mg/L	Nov-19-14	Nov-21-14	
Magnesium, total	34.1	N/A	0.1	mg/L	Nov-19-14	Nov-21-14	
Manganese, total	0.149	AO ≤ 0.05	0.002	mg/L	Nov-19-14	Nov-21-14	
Mercury, total	< 0.0002	MAC = 0.001	0.0002	mg/L	Nov-19-14	Nov-21-14	
Molybdenum, total	0.005	N/A	0.001	mg/L	Nov-19-14	Nov-21-14	
Nickel, total	0.002	N/A	0.002	mg/L	Nov-19-14	Nov-21-14	
Phosphorus, total	< 0.2	N/A	0.2	mg/L	Nov-19-14	Nov-21-14	
Potassium, total	5.8	N/A	0.2	mg/L	Nov-19-14	Nov-21-14	
Selenium, total	0.006	MAC = 0.05	0.005	mg/L	Nov-19-14	Nov-21-14	
Silicon, total	13	N/A	5	mg/L	Nov-19-14	Nov-21-14	
Silver, total	< 0.0005	N/A	0.0005	mg/L	Nov-19-14	Nov-21-14	
Sodium, total	41.0	AO ≤ 200	0.2	mg/L	Nov-19-14	Nov-21-14	
Uranium, total	0.0094	MAC = 0.02	0.0002	mg/L	Nov-19-14	Nov-21-14	
Vanadium, total	< 0.01	N/A	0.01	mg/L	Nov-19-14	Nov-21-14	
Zinc, total	< 0.04	AO ≤ 5	0.04	mg/L	Nov-19-14	Nov-21-14	

**REPORTED TO PROJECT** Alto Utilities Ltd.  
Comprehensive

**WORK ORDER REPORTED** 4110909  
Nov-25-14

Analyte	Result / Recovery	Standard / Guideline	MRL / Units Limits	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------------	----------	----------	-------

**Sample ID: 10397 Lodge Road (Source) North Well (4110909-01) [Water] Sampled: Nov-18-14 11:00, Continued**

**Microbiological Parameters**

Coliforms, Total	< 1	MAC = None Detected	1 CFU/100 mL	Nov-18-14	Nov-19-14	
E. coli	< 1	MAC = None Detected	1 CFU/100 mL	Nov-18-14	Nov-19-14	